



Houston, TX 1999 Steel Potable Water Tank

Manufacturer:

Raven Lining Systems
13105 E. 61st Street,
Suite A
Broken Arrow, OK 74012
(918) 615-0020

Location:

Houston, Texas

Certified Applicator(s):

Lloyd Czerwonka, S&L Industrial Inc.

Owner:

MUDD District 33

Date of Project:

June 1999

Product(s):

[AquataPoxy® A6](#)

Type of Structure(s):

Bolted, galvanized steel, 250,000 gallon potable water tank.

Condition of Structure(s):

Condition before restoration included 72 holes in the shell, seam leaks and 124 holes in floor

Description of Application:

Surface preparation of near white blast was performed. Following surface prep, large holes were patched and fiberglass mesh inlaid. Walls were coated with three coats of AquataPoxy® A6 at 5-8 mils; total DFT of 16-24 mils; floor total DFT of 40 mils. An inspection in 1999 revealed the tank to be in "as good as new" condition.

